

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012034-R5  
DATE: 06/23/2014  
CERTIFICATION PROGRAM: Structural  
COMPANY: Wojan  
CODE: 2087-1  
REVISION DATE: 02/01/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Wojan Window &amp; Door Corporation</b> <b>217 Stover Road</b> <b>Charlevoix, MI 49720</b>	<b>Series "M950"</b> <b>Aluminum Single Hung Window</b>  Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-1372mm(54") H-2184mm(86") Sash: W-1308mm(51.5") H-1118mm(44") DLO: W-1257mm(49.5") H-978mm(38.5")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b> <b>AAMA 910-93</b>	<b>Class AW-PG80 1372 x 2184 (54 x 86)-H</b> <b>H-AW80 1372 x 2184 (54 x 86)</b> <b>Design Pressure: 3840 Pa (80 psf)</b> <b>Negative Design Pressure: 3840 Pa (80 psf)</b> <b>Water Penetration Resistance Test Pressure: 580 Pa(12.11 psf)</b>

Product Tested By: Architectural Testing, Inc.  
Report No: 98457.03-602-44/98457.01-602-44  
Expiration Date: **June 30, 2026**

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)