

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015161
DATE: 02/18/2021
CERTIFICATION PROGRAM: Structural
COMPANY: Wojan
CODE: 2087-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Wojan Window & Door Corporation 217 Stover Road Charlevoix, MI 49720	Series "M950" Thermally-Broken Aluminum Fixed Window Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-1524mm(60") H-2515mm(99") DLO: W-1432mm(56.38") H-2423mm(95.38")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class AW-PG90 1524 x 2515 (60 x 99)-FW Design Pressure: ±4320 Pa (90 psf) Water Penetration Resistance Test Pressure: 730 Pa (15.04 psf)

Product Tested By: Architectural Testing, Inc.
Report No: D7720.01-201-44
Expiration Date: **February 28, 2025**

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122