

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012096-R2
DATE: 08/19/2014
CERTIFICATION PROGRAM: Structural
COMPANY: Eastern
CODE: 1783-1
REVISION DATE: 10/16/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eastern Architectural Systems 16341 Domestic Avenue Ft. Myers, FL 33912	Series "3000" Aluminum Flange Frame Fixed Window Configuration: O Glazing: Monolithic-3/16" Heat Strengthened Glass/0.090" DuPont PVB Interlayer/3/16" Heat Strengthened Glass or IG-3/16" Annealed Glass/Laminate-3/16" Heat Strengthened Glass/0.090" DuPont PVB Interlayer/3/16" Heat Strengthened Glass Frame: W-1219mm(48") H-1372mm(54") DLO: W-1181mm(46.5") H-1333mm(52.5")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA 506-11 ASTM E1886-05/E1996-09 TAS 201/202/203-94	Class CW-PG85 1219 x 1372 (48 x 54)-FW Design Pressure: 4069 Pa (85 psf) Negative Design Pressure: 4309 Pa (90 psf) Water Penetration Resistance Test Pressure: 718 Pa(15.00 psf) Wind Zone 4 - Missile Level D Large Missile Impact Rated

Product Tested By: Certified Testing Laboratories, Inc.
Report No: CTLA 3010W-3/CTLA 3010W-3A CTLA 3010W-1/CTLA 3010W-1A
Expiration Date: May 31, 2027

Administrator's Signature:  _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023