

Hallmark® Certificate of Conformance and License (CCL)



Kolbe & Kolbe Millwork Co.
1323 South 11th Avenue
Wausau, WI 54401

Mfr ID: 413
For more Information visit www.amscert.com
Website: www.kolbewindows.com
TEL:

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
413-H-1284.24	Ultra Folding Door, 3+3, HP (R&D 12192)	101/I.S.2/A440-11	Class -PG65; Size Tested 6110mm x 2570mm Type-SP; DP +65/-65 psf; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=A3	6110mm	2570mm	QCT13-2884.01-R1	1/5/2021	10/17/2023

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  John McFee, VP of Certification Programs, WDMA Hallmark

By:  Lucas L. Wenzel, Authorized Representative, AMS

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com