

# Hallmark® Certificate of Conformance and License (CCL)



Kolbe & Kolbe Millwork Co.  
1323 South 11th Avenue  
Wausau, WI 54401

*Mfr ID:* 413

*For more Information visit* [www.amscert.com](http://www.amscert.com)

*Website:* [www.kolbewindows.com](http://www.kolbewindows.com)

*TEL:*

<i>Product No.</i>	<i>Product Name</i>	<i>Standard</i>	<i>Rating</i>	<i>Wide</i>	<i>High</i>	<i>Test Report #</i>	<i>CertDate</i>	<i>ExpDate</i>
413-H-1294.03	Heritage Majesta Double Hung Studio SP (R&D #12072)	101/I.S.2/A440-11	Class CW-PG70; Size Tested 1829mm x 2438mm Type-FW; DP +70/-75 psf; Water Test Press 510Pa (10.65psf); Can. Air Infil/Exfil. Level=A3	1829mm	2438mm	ESP016817P-1560	7/17/2018	5/23/2024

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

*By:*  John McFee, VP of Certification Programs, WDMA Hallmark

*By:*  Lucas L. Wenzel, Authorized Representative, AMS

Program Sponsor:  
Window and Door Manufacturers Assoc  
330 N. Wabash Avenue, Suite 2000  
Chicago, IL 60611  
TEL (312)673-4828 [www.wdma.com](http://www.wdma.com)

Program Administrator:  
Administrative Management Systems, Inc.  
PO Box 730, 205 West Main  
Sackets Harbor, NY 13685  
TEL (315)646-2234 [staff@amscert.com](mailto:staff@amscert.com)