

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012134.01-R4
DATE: 09/15/2014
CERTIFICATION PROGRAM: Structural
COMPANY: Eastern
CODE: 1783-1
REVISION DATE: 11/10/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eastern Architectural Systems 16341 Domestic Avenue Ft. Myers, FL 33912	Series "5000" Full Glazed Aluminum Outswing Single Side-Hinged Door Configuration: X Glazing: Monolithic Laminate-3/16" Heat Strengthened Glass/0.090" SGP Interlayer by DuPont/3/16" Heat Strengthened Glass or IG-Ext-3/16" Tempered Glass/Laminate-3/16" Heat Strengthened Glass/0.090" SGP Interlayer by DuPont/3/16" Heat Strengthened Glass Frame: W-991mm(39") H-2465mm(97.06") Panel: W-908mm(35.75") H-2388mm(94.03")

SPECIFICATION	PRODUCT RATING
AAMA 506-08 AAMA/WDMA/CSA 101/I.S.2/A440-11 ASTM E1886-05/E1996-09 TAS 201/202/203-94	Design Pressure: 1436 Pa (30 psf) Class LC-PG30 991 x 2465 (39 x 97)-SHD Negative Design Pressure: 4788 Pa (100 psf) Wind Zone 4-Missile Level D Large Missile Impact Rated Water Penetration Resistance Test Pressure: 215 Pa(4.5 psf)

Product Tested By: Certified Testing Laboratories, Inc.
Report No: CTLA-3018WA/CTLA-3018WD
Expiration Date: April 30, 2027

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023