

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012134.02-R2
DATE: 11/20/2014
CERTIFICATION PROGRAM: Structural
COMPANY: Eastern
CODE: 1783-1
REVISION DATE: 10/16/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|--|---|
| Eastern Architectural Systems 16341 Domestic Avenue Ft. Myers, FL 33912 | Series "5000" Full Glazed Aluminum Outswing Double Side-Hinged Door w/Riser Configuration: XX Glazing: Monolithic Laminate-3/16" Heat Strengthened Glass/0.090" SGP Interlayer by DuPont/3/16" Heat Strengthened Glass or IG-Ext-3/16" Tempered Glass/Laminate-3/16" Heat Strengthened Glass/0.090" SGP Interlayer by DuPont/3/16" Heat Strengthened Glass Frame: W-1905mm(75") H-2465mm(97.06") Panel: W-908mm(35.75") H-2388mm(94.03") |

| SPECIFICATION | PRODUCT RATING |
|--|---|
| AAMA 506-08 AAMA/WDMA/CSA 101/I.S.2/A440-11 ASTM E1886-05/E1996-09 TAS 201/202/203-94 | Design Pressure: ±3591 Pa (75 psf) Class LC-PG75 1905 x 2465 (75 x 97)-SHD Wind Zone 4-Missile Level D Large Missile Impact Rated Water Penetration Resistance Test Pressure: 539 Pa(11.25 psf) |

Product Tested By: Certified Testing Laboratories, Inc.
Report No: CTLA-3018WA-1R/CTLA 3018WD-1
Expiration Date: September 30, 2027

Administrator's Signature:  _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023