

Hallmark® Certificate of Conformance and License (CCL)




Marvin
PO Box 100
401 State Ave N.
401 State Ave N.
Warroad, MN 56763

Mfr ID: 407
For more Information visit www.amscert.com
Website: www.marvin.com
TEL: 218-386-1430

<i>Product No.</i>	<i>Product Name</i>	<i>Standard</i>	<i>Rating</i>	<i>Wide</i>	<i>High</i>	<i>Test Report #</i>	<i>CertDate</i>	<i>ExpDate</i>
407-H-1127.75	Ultimate Double Hung/Single Hung G2 6060	101/I.S.2/A440-11	Class LC-PG30; Size Tested 1657 mm x 3239 mm (65-1/4" X 127-1/2") Type-H; DP +30/-30 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3	1657 mm	3239 mm	J1350.01-201-47	1/29/2019	11/29/2028
407-H-1127.76	Ultimate Double Hung/Single Hung G2 6060	101/I.S.2/A440-17	Class LC-PG30; Size Tested 1657 mm x 3239 mm (65-1/4" x 127-1/2")Type-H; DP +30/-30 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3	1657 mm	3239 mm	J1350.01-201-47	1/29/2019	11/29/2028

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  John McFee, VP of Certification Programs, WDMA Hallmark

By:  Lucas L. Wenzel, Authorized Representative, AMS

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com