

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012503-R2
DATE: 02/05/2015
CERTIFICATION PROGRAM: Structural
COMPANY: Nan Ya Plastics
CODE: 661-1
REVISION DATE: 07/30/2018

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Nan Ya Plastics Corporation U.S.A. 8989 North Loop East Houston, TX 77029	<p style="text-align: center;">Series "SLPS"</p> <p style="text-align: center;">In-Swing Glazed Fiberglass</p> <p style="text-align: center;">Side-Hinged Patio Door (Non-Impact)</p> <p style="text-align: center;">Configuration: OXX/O Glazing: Insulating Glass (Tempered)</p> <p>Frame: W-3594mm(141.50") H-2089mm(82.25")</p> <p>Panel: W-876mm(34.50") H-2008mm(79.06")</p> <p>DLO: W-635mm(25.00") H-1600mm(63.00")</p>

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/LS.2/A440-08 CSA A440S1-09	Class R-PG40 3594 x 2089 (142 x 82)-SHD Positive Design Pressure: 2880 Pa (60 psf) Negative Design Pressure: 2880 Pa (60 psf) Water Penetration Resistance Test Pressure: 288 Pa(6.0 psf) Canadian Air Infiltration/Exfiltration Level: A3 Qualified Configurations: O/X/OX/XO/OXO/XX/OXX/XXO/OXX/O/OXX/OXXO

Product Tested By: National Certified Testing Laboratories
 Report No: NCTL-210-3990-01
 Expiration Date: **November 30, 2026**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
 Fax: (804) 684-5122