

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI012619-R2  
**DATE:** 04/20/2015  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Nan Ya Plastics  
**CODE:** 661-1  
**REVISION DATE:** 07/08/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Nan Ya Plastics Corporation U.S.A.</b> <b>8989 North Loop East</b> <b>Houston, TX 77029</b>	<b>Series "SLPS"</b> <b>Out-Swing Glazed Fiberglass</b> <b>Side-Hinged Patio Door (Impact)</b>  Configuration: OXX/O Glazing: IG-1/8" Tempered Glass/1/8" Tempered Glass/0.090" DuPont Butacite PVB Interlayer/1/8" Tempered Glass  Frame: W-3594mm(141.50") H-2089mm(82.25") Panel: W-876mm(34.50") H-2040mm(80.31") DLO: W-635mm(25.00") H-1600mm(63.00")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>CSA A440S1-09</b> <b>ASTM E1886-05/09</b> <b>ASTM E1996-06/09</b>	<b>Class R-PG60 3594 x 2089 (142 x 82)-SHD</b> <b>Positive Design Pressure: 2880 Pa (60 psf)</b> <b>Negative Design Pressure: 2880 Pa (60 psf)</b> Water Penetration Resistance Test Pressure: 432 Pa(9.0 psf) <b>Wind Zone 4 - Missile Level D</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-210-3990-02  
Expiration Date: **January 31, 2031**

Administrator's Signature: \_\_\_\_\_ 

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)