

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI012620.01-R2  
**DATE:** 04/20/2015  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Nan Ya Plastics  
**CODE:** 661-1  
**REVISION DATE:** 08/01/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Nan Ya Plastics Corporation U.S.A.</b> <b>8989 North Loop East</b> <b>Houston, TX 77029</b>	<b>Series "O/XO Gliding Patio Door"</b> <b>Fiberglass Sliding Glass Door</b> <b>w/Field Mullion (Non-Impact)</b>  Configuration: O/XO Glazing: IG-1/8" Tempered Glass/1/8" Annealed Glass  Frame: W-2804mm(110.38") H-2096mm(82.5") Panel: W-908mm(35.75") H-2022mm(79.59") DLO: W-667mm(26.25") H-1676mm(66")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>CSA A440S1-09</b>	<b>Class R-PG50 2804 x 2096 (110 x 83)-SD</b> <b>Design Pressure: ±2400 Pa (±50 psf)</b> <b>Water Penetration Resistance Test Pressure: 360 Pa(7.5 psf)</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-210-3991-02  
Expiration Date: March 31, 2031

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)