

# Hallmark® Certificate of Conformance and License (CCL)




KOLBE & KOLBE MILLWORK CO., INC.  
1323 South 11th Avenue  
Wausau, WI 54401

Mfr ID: 413  
For more Information visit [www.amscert.com](http://www.amscert.com)  
Website:  
TEL:

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
413-H-1289.32	VistaLuxe Outswing Door 3080, 3" Stiles Mullled to a VistaLuxe Direct Set 38x98, SP, (R&D #14109)	101/I.S.2/A440-11	Class LC-PG50; 2494mm Span/965mm Tributary Width (98.19 in./38.00 in.) - MA (Combination Vertical Mull)	965mm	2494mm	ESP0200331P-1739	8/21/2015	7/16/2025
413-H-1289.33	VistaLuxe Outswing Door 3080, 3" Stiles Mullled to a VistaLuxe Direct Set 38x98, SP, (R&D #14109)	101/I.S.2/A440-08	Class LC-PG50; Size Tested 1930mm x 2494mm Type-SHD; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3	1930mm	2494mm	ESP0200331P-1739	8/21/2015	7/16/2025
413-H-1289.34	VistaLuxe Outswing Door 3080, 3" Stiles Mullled to a VistaLuxe Direct Set 38x98, SP, (R&D #14109)	CSA A440 S1-09	Class LC-PG50; Size Tested 1930mm x 2494mm Type-SHD; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3	1930mm	2494mm	ESP0200331P-1739	8/21/2015	7/16/2025
413-H-1289.35	VistaLuxe Outswing Door 3080, 3" Stiles Mullled to a VistaLuxe Direct Set 38x98, SP, (R&D #14109)	AAMA 450-10	Class LC-PG50; 2494mm Span/965mm Tributary Width (98.19 in./38.00 in.) - MA (Combination Vertical Mull)	965mm	2494mm	ESP0200331P-1739	8/21/2015	7/16/2025

WDMA HEREBY CERTIFIES that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected by WDMA, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  **John McFee, VP of Certification Programs, WDMA Hallmark**

By:  **Rhonda Schotz, Authorized Representative, AMS**

Program Sponsor:  
Window and Door Manufacturers Assoc  
330 N. Wabash Avenue, Suite 2000  
Chicago, IL 60611  
TEL (312)673-4828 [www.wdma.com](http://www.wdma.com)

Program Administrator:  
Administrative Management Systems, Inc.  
PO Box 730, 100 West Main  
Sackets Harbor, NY 13685  
TEL (315)646-2234 [staff@amscert.com](mailto:staff@amscert.com)