

Hallmark® Certificate of Conformance and License (CCL)



KOLBE & KOLBE MILLWORK CO., INC.
1323 South 11th Avenue
Wausau, WI 54401

Mfr ID: 413
For more Information visit www.amscert.com
Website:
TEL:

<i>Product No.</i>	<i>Product Name</i>	<i>Standard</i>	<i>Rating</i>	<i>Wide</i>	<i>High</i>	<i>Test Report #</i>	<i>CertDate</i>	<i>ExpDate</i>
413-H-1291.35	VistaLuxe Inswing Door 3080, 3" Stiles mulled to a VistaLuxe Direct Set 38x98, SP (R&D #14110)	101/I.S.2/A440-11	Class LC-PG50; 2494mm Span/940mm Tributary Width (98.19 in./37.00 in.) - MA (Combination Vertical Mull)	940mm	2494mm	ESP020332P-1740	8/21/2015	7/16/2025
413-H-1291.36	VistaLuxe Inswing Door 3080, 3" Stiles mulled to a VistaLuxe Direct Set 38x98, SP (R&D #14110)	101/I.S.2/A440-08	Class LC-PG50; Size Tested 1930mm x 2494mm Type-SHD; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3	1930mm	2494mm	ESP020332P-1740	8/21/2015	7/16/2025
413-H-1291.37	VistaLuxe Inswing Door 3080, 3" Stiles mulled to a VistaLuxe Direct Set 38x98, SP (R&D #14110)	CSA A440 S1-09	Class LC-PG50; Size Tested 1930mm x 2494mm Type-SHD; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3	1930mm	2494mm	ESP020332P-1740	8/21/2015	7/16/2025
413-H-1291.38	VistaLuxe Inswing Door 3080, 3" Stiles mulled to a VistaLuxe Direct Set 38x98, SP (R&D #14110)	AAMA 450-10	Class LC-PG50; 2494mm Span/940mm Tributary Width (98.19 in./37.00 in.) - MA (Combination Vertical Mull)	940mm	2494mm	ESP020332P-1740	8/21/2015	7/16/2025

WDMA HEREBY CERTIFIES that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected by WDMA, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  *John McFee, VP of Certification Programs, WDMA Hallmark*

By:  *Rhonda Schotz, Authorized Representative, AMS*

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 100 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com