

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013898.01-R1
DATE: 11/16/2017
CERTIFICATION PROGRAM: Structural
COMPANY: Nan Ya
CODE: 661-1
REVISION DATE: 09/29/2020

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Nan Ya Plastics Corporation USA 8989 North Loop East, Suite 800 Houston, TX 77029	Series "PRBJ" Fiberglass Outswing Folding Door Configuration: XXXX Glazing: Insulating Glass (Ext-Tempered/Int-Annealed) Frame: W-3567mm(140.44") H-2483mm(97.75") Panel: W-876mm(34.5") H-2370mm(93.31") DLO: W-635mm(25") H-2007mm(79")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 CSA A440S1-09	Class PG60 3567 x 2483 (140 x 98)-SP Design Pressure: 2880 Pa (60 psf) Water Penetration Resistance Test Pressure: 432 Pa (9.0 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-4088-02
Expiration Date: September 30, 2025

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122