

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI013898.02-R2  
**DATE:** 03/13/2019  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Nan Ya  
**CODE:** 661-1  
**REVISION DATE:** 09/29/2020

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Nan Ya Plastics Corporation USA</b> <b>8989 North Loop East, Suite 800</b> <b>Houston, TX 77029</b>	<b>Series "PRBJ" Fiberglass</b> <b>Outswing Folding Door</b>  Configuration: XXXX Glazing: IG-1/8" Tempered Glass/Laminate-1/8" Annealed Glass/0.090" Kuraray PVB Interlayer/1/8" Annealed Glass  Frame: W-3567mm(140.44") H-2483mm(97.75") Panel: W-876mm(34.5") H-2370mm(93.31") DLO: W-635mm(25") H-2007mm(79")

SPECIFICATION	PRODUCT RATING
<b>ASTM E1886-05/E1996-05/09</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>CSA A440S1-09</b>	<b>Class PG50 3567 x 2483 (140 x 98)-SP</b> <b>Design Pressure: 2400 Pa (50 psf)</b> Water Penetration Resistance Test Pressure: 360 Pa (7.5 psf) <b>Wind Zone 4 - Missile Level D</b> Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: National Certified Testing Laboratories

Report No: NCTL-210-4088-01

Expiration Date: **September 30, 2025**

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Fax: (804) 684-5122