

# Hallmark® Certificate of Conformance and License (CCL)




JELD-WEN INC.  
401 Harbor Isles Boulevard  
Klamath Falls, OR 97601

*Mfr ID:* 406  
*For more Information visit* [www.amscert.com](http://www.amscert.com)  
*Website:* WWW.JELD-WEN.COM  
*TEL:* (541) 882-3451

<i>Product No.</i>	<i>Product Name</i>	<i>Standard</i>	<i>Rating</i>	<i>Wide</i>	<i>High</i>	<i>Test Report #</i>	<i>CertDate</i>	<i>ExpDate</i>
406-H-824.25	Siteline or W-5500 Clad Casement Picture - IG Impact	ASTM E-1996 14/ASTM E-1886 13a	DP +50/-65 psf, Missile D, Wind Zone 3	1067mm	1524mm	SJW2015-111 E1A1	9/9/2020	3/15/2024

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

*By:*  John McFee, VP of Certification Programs, WDMA Hallmark

*By:*  Lucas L. Wenzel, Authorized Representative, AMS

Program Sponsor:  
Window and Door Manufacturers Assoc  
330 N. Wabash Avenue, Suite 2000  
Chicago, IL 60611  
TEL (312)673-4828 [www.wdma.com](http://www.wdma.com)

Program Administrator:  
Administrative Management Systems, Inc.  
PO Box 730, 205 West Main  
Sackets Harbor, NY 13685  
TEL (315)646-2234 [staff@amscert.com](mailto:staff@amscert.com)