

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI011584-R4  
**DATE:** 06/12/2013  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Regency  
**CODE:** 750-1  
**REVISION DATE:** 01/09/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Regency Plus, Inc.</b> <b>2000 Locust Gap Highway</b> <b>Mount Carmel, PA 17851</b>	<b>Series "7213"</b> <b>Vinyl Casement Window</b>  Configuration: X Glazing: Insulating Glass (Tempered)  Frame: W-914mm(36") H-1727mm(68") Vent: W-870mm(34.25") H-1683mm(66.25)

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b>	<b>Class LC-PG50 914 x 1727 (36 x 68)-C</b> <b>C-LC50 914 x 1727 (36 x 68)</b> <b>Design Pressure: 2400 Pa (50 psf)</b> <b>Negative Design Pressure: 2400 Pa (50 psf)</b> <b>Water Penetration Resistance Test Pressure: 470 Pa (9.75 psf)</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-15927-1/W-1901/W-1979  
Expiration Date: April 30, 2029

Administrator's Signature: 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)