

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011582-R4
DATE: 06/12/2013
CERTIFICATION PROGRAM: Structural
COMPANY: Regency
CODE: 750-1
REVISION DATE: 01/09/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Regency Plus, Inc. 2000 Locust Gap Highway Mount Carmel, PA 17851	Series "7413" Vinyl Horizontal Sliding Window Configuration: XO Glazing: Insulating Glass (Tempered) Frame: W-1880mm(74") H-1600mm(63") Panel: W-911mm(35.87") H-1524mm(60)

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	Class LC-PG50 1880 x 1600 (74 x 63)-HS HS-LC50 1880 x 1600 (74 x 63) Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 470 Pa (9.75 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-15926-1/W-1901/W-1979
Expiration Date: **May 31, 2029**

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com