

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013035  
DATE: 03/07/2016  
CERTIFICATION PROGRAM: Structural  
COMPANY: Masonite  
CODE: 703-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Masonite</b> <b>1955 Powis Road</b> <b>West Chicago, IL 60185</b>	<b>Masonite Horizontal</b> <b>Wood Mullion</b>  Span: 1765mm(69.5") Tributary Width: 1219mm(50.44")

SPECIFICATION	PRODUCT RATING
<b>AAMA 450-10</b>	<b>Applied Rating: Class R-PG55</b> <b>Mulled Fenestration Rating: Class R-PG55-MA</b> <b>Design Pressure: ±2633 Pa (55 psf)</b> <b>Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf)</b>

Product Tested By: National Certified Testing Laboratories, Inc.  
Report No: NCTL-110-18296-2  
Expiration Date: March 31, 2020

A handwritten signature in black ink, appearing to be "S.M.", written over a horizontal line.

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122