

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013035-R2
DATE: 03/07/2016
CERTIFICATION PROGRAM: Structural
COMPANY: Masonite
CODE: 703-1
REVISION DATE: 11/14/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Masonite 1955 Powis Road West Chicago, IL 60185	Masonite Horizontal Wood Mullion Span: 1765mm(69.5") Tributary Width: 1219mm(50.44")

SPECIFICATION	PRODUCT RATING
AAMA 450-10	Applied Rating: Class R-PG55 Mulled Fenestration Rating: Class R-PG55-MA Design Pressure: ± 2633 Pa (55 psf) Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf)

Product Tested By: National Certified Testing Laboratories, Inc.
Report No: NCTL-110-18296-2
Expiration Date: March 31, 2027

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com