

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI013081-R3  
**DATE:** 03/30/2016  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Air Master  
**CODE:** 2142-1  
**REVISION DATE:** 08/17/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Air Master Awning, LLC</b> <b>Road PR #2 interior KM 56.7</b> <b>Barceloneta, PR 00617</b>	<b>Series "Continental"</b> <b>Aluminum Side-Hinged Door</b> <b>w/Sidelites</b>  Configuration: OXXO Glazing: Monolithic- 3/16" Annealed Glass/0.090" Eastman Chemical Saflex CP Composite Interlayer w/PET Core w/Saflex HP/3/16" Annealed Glass or IG- 3/16 Tempered Glass/3/16" Annealed Glass/0.090" Eastman Chemical Saflex CP Composite Interlayer w/PET Core w/Saflex HP/3/16" Annealed Glass  Frame: W3566mm(140.38") H-2473mm(97.38") Panel: W-872mm(34.31") H-2397mm(94.38") DLO: W-683mm(26.88") H-2289mm(90.13")

SPECIFICATION	PRODUCT RATING
<b>TAS 201/202/203-94</b>	<b>Design Pressure: ±3591 Pa (75 psf)</b> <b>Large Missile Impact Rated</b>

Product Tested By: Blackwater Testing, Inc.  
Report No: BT-AM-12-005/BT-AM-14-001(A)/BT-AM-15-002A/W-2000  
Expiration Date: March 31, 2032

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)