

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI013191-R2  
**DATE:** 05/17/2016  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Air Master  
**CODE:** 2142-1  
**REVISION DATE:** 08/17/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p><b>Air Master Awning, LLC</b>  <b>Road PR #2 interior KM 56.7</b>  <b>Barceloneta, PR 00617</b></p>	<p style="text-align: center;"><b>Series "Continental"</b>  <b>Aluminum Casement Window</b></p> <p style="text-align: center;">Configuration: X                      Glazing: Monolithic- 1/8" Heat Strengthened Glass/0.090" Eastman Chemical Saflex PVB Interlayer/1/8" Heat Strengthened Glass or Insulating Glass- 1/4" Tempered Glass/1/8" Heat Strengthened Glass/0.090" Eastman Chemical Saflex PVB Interlayer/1/8" Heat Strengthened Glass</p> <p>Frame:     W914mm(36")         H-1829mm(72")                      Vent:       W-823mm(32.44")     H-1765mm(69.50")                      DLO:       W-730mm(28.75")     H-1673mm(65.88")</p>

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	<b>Design Pressure: ±3352 Pa (70 psf)</b> <b>Large Missile Impact Rated</b>

Product Tested By: Blackwater Testing, Inc.  
 Report No: BT-AM-15-001  
 Expiration Date: **February 28, 2032**

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
 MANAGEMENT INSTITUTE, INC.**  
 4794 George Washington Memorial Highway  
 Hayes, VA 23072  
 Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)