



AAMA CERTIFICATION PROGRAM
An FGIA Product Certification Program



AUTHORIZATION FOR PRODUCT CERTIFICATION

MI Windows & Doors, LLC
P.O. Box 370
Gratz, PA 17030-0370

Attn: Rick Sawdey

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATION	RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-17 LC-PG30-3048x1600 (120x63)-HS				
COMPANY AND CODE	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
MI Windows & Doors, LLC Code: MTL	18923	1630 HS (FIN) (PVC)(XOX)(OG)(INS GL) (MODIF)(REINF)(ASTM)	FRAME 3048 mm x 1600 mm (10'0" x 5'3")	SASH 1016 mm x 1524 mm (3'4" x 5'0")
Design Pressure (psf): +40/-30 (Pa): +1920/-1440			Water Test Pressure (psf): 7.52 (Pa): 360	


This Certification will expire **March 27, 2025** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Product Tested and Reported by: **Molimo, LLC**

Report No.: **2276.02-106-12**

Date of Report: **April 21, 2020**

Evaluated for Certification: **May 1, 2020**


Associated Laboratories, Inc.

Authorized for Certification: **May 1, 2020**



Fenestration and Glazing Industry Alliance



(Validator / Operations Administrator)

ACP-04 (Rev. 2/20)