NOTICE OF PRODUCT CERTIFICATION



Company: Nan Ya Plastics Corporation

8989 North Loop East Houston, TX 77029 Certification No.: NI010023-R4 Pg6

 Certification Date:
 09/09/2009

 Expiration Date:
 06/30/2025

 Revision Date:
 09/29/2020

Product: Series "NI-3" Fiberglass Skin Opaque Double Entry Door (PVC Frame)

Specification: TAS 202-94

The "Notice of Product Certification" is only valid if the NAMI Certification Label has been applied to the product as described within this document. The certification label represents product conformity to the applicable specification and that all certification criteria has been satisfied. This product has been approved for listing within NAMI's Certified Product Listing at www.Namicertification.com. NAMI's Certification Program is accredited by The American National Standards Institute (ANSI).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Structural Design Pressure	Missile Impact Rated	Test Report Number Drawing Number & Comments
X Single	O/S	Opaque	3'1" x 6'9"	+50/-55 psf	No	ETC-07-255-18448.5
X Single	I/S	Opaque	3'1" x 6'10"	+30/-50 psf	No	ETC-07-255-18448.5
XX Double	O/S	Opaque	6'2" x 6'9"	+50/-55 psf	No	ETC-07-255-18448.5
XX Double	I/S	Opaque	6'2" x 6'10"	+30/-50 psf	No	ETC-07-255-18448.5

National Accreditation & Management Institute, Inc./4794 George Washington Memorial Highway/Hayes, VA 23072 Tel: (804) 684-5124/Fax: (804) 684-5122

NAMI AUTHORIZED SIGNATURE: