



AAMA CERTIFICATION PROGRAM
An FGIA Product Certification Program



AUTHORIZATION FOR PRODUCT CERTIFICATION

JELD-WEN Windows & Doors
P.O. Box 1329
Klamath Falls, OR 97601

Attn: Joshua Goossen

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-08 R-PG50-1822x2027 (72x80)-SD Negative Design Pressure = -65 psf		AAMA 506			
COMPANY AND CODE	Missile Level: D Rating: +50/-65, 72x80 Wind Zone: 3 Rating above conforms to the requirements of: ASTM E1886 and E1996	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
JELD-WEN Windows & Doors Code: JW		16512	PREMIUM VINYL (V-4500) SGD (FIN & FINLESS) (PVC)(OX)(OG) (INS TEMP/0.090" PVB LAM GL)(MODIF)(REINF) (ASTM)	<u>FRAME (mm)</u> 1822 x 2027 (6'0" x 6'8")	<u>PANELS (mm)</u> 945 x 1959 (3'1" x 6'5")

This Certification will expire **March 21, 2026 (extended from March 21, 2021 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Structural Test & Report By:

Intertek-ATI & National Certified Testing Laboratories

Report No: **G0960.02-301-47; ref. SJW2016-009**

Date of Report: **September 27, 2016 (Revised October 13, 2016);**
April 26, 2016


Missile Impact Test & Report By:

Intertek-ATI

Report No: **G0960.02-301-47**

Date of Report: **September 27, 2016**
(Revised October 13, 2016)

Evaluated for Certification: **August 14, 2020**


Associated Laboratories, Inc.

Authorized for Certification: **August 14, 2020**



Fenestration and Glazing Industry Alliance



(Validator / Operations Administrator)

ACP-04 (Rev. 2/20)