

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI013706.02-R1  
**DATE:** 05/08/2017  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** JELD-WEN  
**CODE:** 1822-1  
**REVISION DATE:** 05/17/2017

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>JELD-WEN</b> <b>3737 Lakeport Boulevard</b> <b>Klamath Falls, OR 97601</b>	<b>Premium Vinyl (V4500)</b> <b>Multi-Slide Sliding Patio Door</b>  Configuration: OXXXXX Glazing: IG-3/16" Tempered Glass/3/16" Annealed Glass/0.090" SGP Interlayer/3/16" Annealed Glass  Frame: W-7130mm(280.44") H-3050mm(120.06") Panel: W-1290mm(50.81") H-2978mm(117.25") DLO: W-1034mm(41.44") H-2770mm(109.06")

SPECIFICATION	PRODUCT RATING
<b>TAS 201/202/203-94</b>	<b>Design Pressure: ±2873 Pa (60 psf)</b> Water Penetration Resistance Test Pressure: 470 Pa (9.82 psf) <b>Large Missile Impact Rated</b>

Product Tested By: Architectural Testing, Inc.  
Report No: G6556.04-301-44  
Expiration Date: **January 31, 2025**

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122