

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013706-R1
DATE: 05/08/2017
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 05/17/2017

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Premium Vinyl (V4500) Multi-Slide Sliding Patio Door Configuration: XXXX Glazing: IG-3/16" Tempered Glass/3/16" Annealed Glass/0.090" SGP Interlayer/3/16" Annealed Glass Frame: W-4852mm(191") H-3048mm(120") Panel: W-1290mm(50.81") H-2978mm(117.25") DLO: W-1034mm(41.44") H-2769mm(109")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: ±2873 Pa (60 psf) Water Penetration Resistance Test Pressure: 470 Pa (9.82 psf) Large Missile Impact Rated

Product Tested By: Architectural Testing, Inc.
Report No: G6547.02-301-44
Expiration Date: **January 31, 2025**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122