

# Hallmark® Certificate of Conformance and License (CCL)



Kolbe & Kolbe Millwork Co.  
1323 South 11th Avenue  
Wausau, WI 54401

**Mfr ID:** 413


*For more Information visit [www.amscert.com](http://www.amscert.com)*

**Website:** [www.kolbewindows.com](http://www.kolbewindows.com)

**TEL:**

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
413-H-1142.32	Ultra Pushout Casement Segment Head & Quarter Circle, EE, IPD4, IG (R&D #16090 & 16092)	101/I.S.2/A440-11	Class CW-PG65; Size Tested 914mm x 1829mm Type-C; DP +65/-65 psf; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=A2	914mm	1829mm	ESP023976P-2059.1	1/4/2017	10/6/2026
413-H-1142.34	Ultra Pushout Casement Half Circle, EE, IPD4, IG (R&D #16091)	101/I.S.2/A440-11	Class LC-PG65; Size Tested 914mm x 1829mm Type-C; DP +65/-65 psf; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=A2	914mm	1829mm	ESP023976P-2059.1	12/30/2016	10/6/2026
413-H-1142.37	Ultra Pushout Casement Segment Head, Half Circle, & Quarter Circle, EE, IPD4, IG (R&D #16090, 16091, & 16092)	ASTM E-1996 12/ASTM E-1886-05	DP +65/-65 psf, Missile D, Wind Zone 4	914mm	1829mm	ESP023976P-2059.1	1/4/2017	10/6/2026
413-H-1142.38	Ultra Pushout Casement Segment Head & Half Circle, EE, IPD4, SG (R&D #16087 & 16088)	101/I.S.2/A440-11	Class CW-PG65; Size Tested 914mm x 1829mm Type-C; DP +65/-65 psf; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=A3	914mm	1829mm	ESP023976P-2059	12/30/2016	10/5/2026
413-H-1142.40	Ultra Pushout Casement Quarter Circle, EE, IPD4, SG (R&D #16089)	101/I.S.2/A440-11	Class LC-PG65; Size Tested 914mm x 1829mm Type-C; DP +65/-65 psf; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=A3	914mm	1829mm	ESP023976P-2059	12/30/2016	10/5/2026
413-H-1142.43	Ultra Pushout Casement Segment Head, Half Circle, & Quarter Circle, EE, IPD4, SG (R&D #16087, 16088, & 16089)	ASTM E-1996 12/ASTM E-1886-05	DP +65/-65 psf, Missile D, Wind Zone 4	914mm	1829mm	ESP023976P-2059	12/30/2016	10/5/2026

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

**By:**  John McFee, VP of Certification Programs, WDMA Hallmark

**By:**  Lucas L. Wenzel, Authorized Representative, AMS

Program Sponsor:  
Window and Door Manufacturers Assoc  
330 N. Wabash Avenue, Suite 2000  
Chicago, IL 60611  
TEL (312)673-4828 [www.wdma.com](http://www.wdma.com)

Program Administrator:  
Administrative Management Systems, Inc.  
PO Box 730, 205 West Main  
Sackets Harbor, NY 13685  
TEL (315)646-2234 [staff@amscert.com](mailto:staff@amscert.com)