

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013482.02-R3
DATE: 01/18/2017
CERTIFICATION PROGRAM: Structural
COMPANY: Eastern
CODE: 1783-1
REVISION DATE: 10/16/2027

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eastern Architectural Systems 16341 Domestic Avenue Ft. Myers, FL 33912	Series "176 HRP 4-2-4" Vinyl Horizontal Slider (Fin Installation) Configuration: XOX Glazing: Insulating Glass (Annealed) Frame: W-2819mm(111") H-1600mm(63") Panel: W-1467mm(57.75") H-1538mm(60.56")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class LC-PG55 2819 x 1600 (111 x 63)-HS Design Pressure: 2640 Pa (55 psf) Negative Design Pressure: 2880 Pa (60 psf) Water Penetration Resistance Test Pressure: 504 Pa(10.5 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-4039-05
Expiration Date: **September 30, 2027**

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com