

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013481-R2  
DATE: 01/18/2017  
CERTIFICATION PROGRAM: Structural  
COMPANY: Eastern  
CODE: 1783-1  
REVISION DATE: 10/16/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Eastern Architectural Systems</b> <b>16341 Domestic Avenue</b> <b>Ft. Myers, FL 33912</b>	<b>Series "176"</b> <b>Vinyl Fixed Window</b>  (Fin or Flange Installation) Configuration: O Glazing: Insulating Glass (Annealed)  Frame: W-1524mm(60") H-1524mm(60") DLO: W-1397mm(55") H-1397mm(55")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class CW-PG90 1524 x 1524 (60 x 60)-FW</b> <b>Design Pressure: ±4320 Pa (90 psf)</b> Water Penetration Resistance Test Pressure: 720 Pa(15 psf)

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-210-4044-01  
Expiration Date: **September 30, 2027**

Administrator's Signature:  \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Email: [nami@namiinc.com](mailto:nami@namiinc.com)