

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013310.01-R2
DATE: 07/21/2016
CERTIFICATION PROGRAM: Structural
COMPANY: Nan Ya
CODE: 661-1
REVISION DATE: 08/10/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p>Nan Ya Plastics Corporation USA 8989 North Loop East, Suite 800 Houston, TX 77029</p>	<p style="text-align: center;">Series "SLPS" Inswing Glazed Fiberglass Side-Hinged Patio Door (Impact)</p> <p style="text-align: center;">Configuration: OXX/O Glazing: IG-1/8" Tempered Glass/1/8" Heat Strengthened Glass/0.090" Kuraray PVB Interlayer/1/8" Heat Strengthened Glass</p> <p>Frame: W-3594mm(141.5") H-2419mm(95.25") Panel: W-876mm(34.5") H-2338mm(92.06") DLO: W-533mm(21") H-2007mm(79")</p>

SPECIFICATION	PRODUCT RATING
<p>ASTM E1886-05 ASTM E1996-05/09 AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09</p>	<p>Class R-PG40 3594 x2419 (142 x 95)-SHD Design Pressure: ±1920 Pa (40 psf) Positive Design Pressure: 2880 Pa (60 psf) Negative Design Pressure: 2880 Pa (60 psf) Water Penetration Resistance Test Pressure: 288 Pa (6.0 psf) Canadian Air Infiltration/Exfiltration Level: A2 Wind Zone 4 - Missile Level D Qualifies Configurations: O/X/OXX/O/XXO/O/O/X/O/O/X/OX/O/XO/O/OXX/O/O/XXO</p>

Product Tested By: National Certified Testing Laboratories
 Report No: NCTL-210-4020-02
 Expiration Date: May 31, 2032

Administrator's Signature: _____

NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124/ Email: nami@namiinc.com