

AAMA CERTIFICATION PROGRAM An FGIA Product Certification Program

An FGIA Product Certification Program



AUTHORIZATION FOR PRODUCT CERTIFICATION

JELD-WEN Windows & Doors P.O. Box 1329 Klamath Falls, OR 97601

Attn: Joshua Goossen

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATIONS				
AAMA/WDMA/CSA 101/I.S.2/A440-11 LC-PG50-1524x1524 (60x60)-FW Negative Design Pressure = -55 psf	AAMA 506	RECORD OF PRODUCT TESTED		
COMPANY AND CODE	Missile Level: C Rating: +50/-55, 60x60 Wind Zone: 2 Rating above conforms to the requirements of: ASTM E1886 and E1996	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED
JELD-WEN Windows & Doors Code: JW		16378	PREMIUM VINYL (V-4500) PW W/TRACK FILLER (FIN & FINLESS) (PVC)(O)(OG) (INS 0.060" PVB LAM GL) (MODIF)(ASTM)	<u>FRAME</u> 1524 mm x 1524 mm (5'0" x 5'0")

This Certification will expire February 7, 2027 (extended from February 7, 2022 per AAMA 103-19) and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Structural Test & Report By:

National Certified Testing Laboratories Report No: SJW2014-064 Date of Report: June 13, 2014 (Revised June 20, 2014) Missile Impact Test & Report By:

National Certified Testing Laboratories Report No: NCTL-110-17-038 Date of Report: March 8, 2017

Evaluated for Certification: April 5, 2021

sociated Laboratories, Inc.

Authorized for Certification: April 5, 2021

Fenestration and Glazing Industry Alliance



(Validator / Operations Administrator)

ACP-04 (Rev. 2/20)