



AAMA CERTIFICATION PROGRAM
An FGIA Product Certification Program



AUTHORIZATION FOR PRODUCT CERTIFICATION

JELD-WEN Windows & Doors
P.O. Box 1329
Klamath Falls, OR 97601

Attn: Joshua Goossen

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATION	RECORD OF PRODUCT TESTED			
COMPANY AND CODE	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
AAMA/WDMA/CSA 101/I.S.2/A440-08 LC-PG50-1321x1905 (52x75)-H Negative Design Pressure = -55 psf	16227	PREMIUM VINYL (V-4500) TILT SH (FIN & FINLESS) (PVC)(O/X)(OG)(INS GL) (MODIF)(REINF)(TILT)(ASTM)	<u>FRAME</u> 1321 mm x 1905 mm (4'4" x 6'3")	<u>SASH</u> 1260 mm x 932 mm (4'2" x 3'1")
JELD-WEN Windows & Doors Code: JW				


This Certification will expire **December 8, 2026 (extended from December 8, 2021 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Product Tested and Reported by: **National Certified Testing Laboratories**

Report No.: **NCTL-110-16-150**

Date of Report: **December 14, 2016**

Evaluated for Certification: **January 22, 2021**


 Associated Laboratories, Inc.

Authorized for Certification: **January 22, 2021**


 Fenestration and Glazing Industry Alliance



(Validator / Operations Administrator)