



AAMA CERTIFICATION PROGRAM
An FGIA Product Certification Program



AUTHORIZATION FOR PRODUCT CERTIFICATION

JELD-WEN Windows & Doors
P.O. Box 1329
Klamath Falls, OR 97601

Attn: Joshua Goossen

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATION	RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-11 LC-PG50-1219x1956 (48x77)-H Negative Design Pressure = -55 psf				
COMPANY AND CODE	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
JELD-WEN Windows & Doors Code: JW	16615	PREMIUM VINYL (V-4500) DH (FIN & FINLESS) (PVC)(X/X)(OG)(INS GL) (MODIF)(REINF)(TILT)(ASTM)	FRAME 1219 mm x 1956 mm (4'0" x 6'5")	SASH 1156 mm x 968 mm (3'9" x 3'2")


This Certification will expire **February 6, 2027 (extended from February 6, 2022 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Product Tested and Reported by: **Element Materials Technology**

Report No.: **ESP024843P.6Rev**

Date of Report: **March 15, 2017 (Revised May 16, 2017)**

Evaluated for Certification: **April 22, 2021**


 Associated Laboratories, Inc.

Authorized for Certification: **April 22, 2021**


 Fenestration and Glazing Industry Alliance

