

AAMA CERTIFICATION PROGRAM

An FGIA Product Certification Program



AUTHORIZATION FOR PRODUCT CERTIFICATION

JELD-WEN Windows & Doors P.O. Box 1329 Klamath Falls, OR 97601

Attn: Joshua Goossen

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATIONS					
AAMA/WDMA/CSA 101/I.S.2/A440-11 LC-PG50*-2743x1829 (108x72)-H	AAMA 506	RECORD OF PRODUCT TESTED			
COMPANY AND CODE	Missile Level: D Rating: +50/-50, 108x72 Wind Zone: 3	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
JELD-WEN Windows & Doors Code: JW	Rating above conforms to the requirements of: ASTM E1886 and E1996	17197	PREMIUM VINYL (V-4500) TRIPLE DH (FIN & FINLESS) (PVC)(X/X.X/X.X/X)(OG) (INS 0.090" PVB LAM GL) (MODIF)(REINF)(TILT)(ASTM)	FRAME (mm) 2743 x 1829 (9'0" x 6'0")	SASH (mm) 816 x 876 (2'8" x 2'11")

This Certification will expire May 19, 2027 (extended from May 19, 2022 per AAMA 103-19) and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Structural Test & Report By:

Element Materials Technology

Report No: **ESP024843P.7**

Date of Report: May 22, 2017

Missile Impact Test & Report By:

Intertek B&C

Report No: H8907.06-301-47

Date of Report: January 3, 2018

Evaluated for Certification: April 22, 2021

Associated Laboratories, Inc.

Authorized for Certification: April 22, 2021

Fenestration and Glazing Industry Alliance

A·L·I

(Validator / Operations Administrator)

ACP-04 (Rev. 2/20)