

NOTICE OF PRODUCT CERTIFICATION



Company: Masonite International Corporation
 1955 Powis Road
 West Chicago, IL 60185

Certification No.: NI013717.04-R1
Certification Date: 05/12/2017
Expiration Date: 05/31/2021
Revision Date: 11/20/2017

Product: Fiberglass Glazed Inswing or Outswing Door w/ and w/o Non-Impact Rated Sidelites
 3/4 Lite of Less Doors w/ and w/o Full-Lite or Less Sidelites (w/Wood Frame or Worldwide
 Composite Frame⁴ unless noted)

Specification: TAS 202-94/ASTM E330-02 **Glazing:** Insulating Glass (Tempered)

The "Notice of Product Certification" is only valid if the NAMI Certification Label has been applied to the product as described within this document. The certification label represents product conformity to the applicable specification and that all certification criteria has been satisfied. This product has been approved for listing within NAMI's Certified Product Listing at www.Namicertification.com. NAMI's Certification Program is accredited by The American National Standards Institute (ANSI).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Structural Design Pressure	Water Test Pressure	Missile Impact Rated	Test Report Number Drawing Number & Comments
X Single	I/S	Glazed 3/4-Lite Max	3'0" x 6'8"	+50/-50	0.0 psf	No	ATLNC 1012.01-16R Maximum Panel Size: 3'0" x 6'8" Anchor Details-DWG-MA-FL0193-17
X Single	O/S	Glazed 3/4-Lite Max	3'0" x 6'8"	+50/-50	3.75 psf ¹ 6.0 psf ² 8.25 psf ³ 9.0 psf ⁵	No	ATLNC 1012.01-16R/W-1813/W-1843 Maximum Panel Size: 3'0" x 6'8" Anchor Details-DWG-MA-FL0193-17
XX Double	I/S	Glazed 3/4-Lite Max	6'0" x 6'8"	+50/-50	0 psf	No	ATLNC 1012.01-16R Maximum Panel Size: 3'0" x 6'8" Anchor Details-DWG-MA-FL0193-17
XX Double	O/S	Glazed 3/4-Lite Max	6'0" x 6'8"	+50/-50	3.75 psf ¹ 6.0 psf ² 8.25 psf ³ 8.25 psf ⁵	No	ATLNC 1012.01-16R/W-1813/W-1843 Maximum Panel Size: 3'0" x 6'8" Anchor Details-DWG-MA-FL0193-17
XO/OX Single w/Sidelite	I/S	Glazed 3/4-Lite Max Full-Lite Max S/L	6'0" x 6'8"	+50/-50	0 psf	Door-No Sidelite-No	ATLNC 1012.01-16R Maximum Panel Size: 3'0" x 6'8" Anchor Details-DWG-MA-FL0193-17
XO/OX Single w/Sidelite	O/S	Glazed 3/4-Lite Max Full-Lite Max S/L	6'0" x 6'8"	+50/-50	3.75 psf ¹ 6.0 psf ² 8.25 psf ³ 9.0 psf ⁵	Door-No Sidelite-No	ATLNC 1012.01-16R/W-1813/W-1843 Maximum Panel Size: 3'0" x 6'8" Anchor Details-DWG-MA-FL0193-17
OXO Single w/Sidelites	I/S	Glazed 3/4-Lite Max Full-Lite Max S/L	9'0" x 6'8"	+50/-50	0 psf	Door-No Sidelites-No	ATLNC 1012.01-16R Maximum Panel Size: 3'0" x 6'8" Anchor Details-DWG-MA-FL0193-17
OXO Single w/Sidelites	O/S	Glazed 3/4-Lite Max Full-Lite Max S/L	9'0" x 6'8"	+50/-50	3.75 psf ¹ 6.0 psf ² 8.25 psf ³ 9.0 psf ⁵	Door-No Sidelites-No	ATLNC 1012.01-16R/W-1813/W-1843 Maximum Panel Size: 3'0" x 6'8" Anchor Details-DWG-MA-FL0193-17
OXXO Double w/Sidelites	I/S	Glazed 3/4-Lite Max Full-Lite Max S/L	12'4" x 6'8"	+50/-50	0 psf	Door-No Sidelites-No	ATLNC 1012.01-16R Maximum Panel Size: 3'0" x 6'8" Anchor Details-DWG-MA-FL0193-17
OXXO Double w/Sidelites	O/S	Glazed Glazed 3/4-Lite Max Full-Lite Max S/L	12'4" x 6'8"	+50/-50	3.75 psf ¹ 6.0 psf ² 8.25 psf ³ 8.25 psf ⁵	Door-No Sidelites-No	ATLNC 1012.01-16R/W-1813/W-1843 Maximum Panel Size: 3'0" x 6'8" Anchor Details-DWG-MA-FL0193-17

1 -Denotes Bumper Outswing Threshold 2 -Denotes Z-Series Outswing Threshold 3-Hi-Dam Outswing Threshold 4-W-1815 5-Worldwide Pro T4 Threshold

National Accreditation & Management Institute, Inc./4794 George Washington Memorial Highway/Hayes, VA 23072

Tel: (804) 684-5124/Fax: (804) 684-5122

NAMI AUTHORIZED SIGNATURE: _____