



AAMA CERTIFICATION PROGRAM
An FGIA Product Certification Program



AUTHORIZATION FOR PRODUCT CERTIFICATION

JELD-WEN Windows & Doors
P.O. Box 1329
Klamath Falls, OR 97601

Attn: Joshua Goossen

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-11 LC-PG50*-2438x1524 (96x60)-HS Negative Design Pressure = -55 psf	AAMA 506				
COMPANY AND CODE	Missile Level: D Rating: +50/-55, 96x60 Wind Zone: 3 Rating above conforms to the requirements of: ASTM E1886 and E1996	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
JELD-WEN Windows & Doors Code: JW		16925	PREMIUM VINYL (V-4500) HS (FIN & FINLESS) (PVC)(XOX)(OG) (INS TEMP/0.090" PVB LAM GL)(MODIF)(REINF) (ASTM)	<u>FRAME (mm)</u> 2438 x 1524 (8'0" x 5'0")	<u>SASH (mm)</u> 584 x 1454 (1'11" x 4'9")

This Certification will expire **June 20, 2027 (extended from June 20, 2022 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Structural Test & Report By:

Element Materials Technology

Report No: **ESP025820P.6**

Date of Report: **June 29, 2017**

Missile Impact Test & Report By:

Intertek B&C

Report No: **H5874.04-301-47**

Date of Report: **October 6, 2017**

Evaluated for Certification: **June 19, 2020**

Associated Laboratories, Inc.

Authorized for Certification: **June 19, 2020**

Fenestration and Glazing Industry Alliance



(Validator / Operations Administrator)

ACP-04 (Rev. 2/20)