

NOTICE OF PRODUCT CERTIFICATION



Company: Masonite International Corporation
1955 Powis Road
West Chicago, IL 60185

Certification No.: NI007077.04-R8
Certification Date: 04/10/2007
Expiration Date: 12/31/2026
Revision Date: 12/06/2023

Product: Fiberglass Impact Rated Glazed Inswing or Outswing Door w/ and w/o Impact Rated Sidelites
(w/Wood Frame or Worldwide Composite Frame³ unless noted)

Specification: TAS 201/202/203-94/ASTM E330-02/14/M-14

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Structural Design Pressure	Water Test Pressure	Missile Impact Rated	Test Report Number Drawing Number & Comments
X Single	I/S	Glazed	3'0" x 8'0"	+43/-47	0 psf	Yes	NCTL-210-3367-1/ATLNC 1118.01-14/ATLNC 1031.01-16 Maximum Panel Size: 3'0" x 8'0" Anchor Details-MA-FL0173-07/W-1807/W-1885/W-2106
X Single	O/S	Glazed	3'0" x 8'0"	+47/-45 +55/-55 w/Surface Bolts	3.75 psf/ 6.0 psf ¹ 8.25 psf ² /9.0 psf ⁴	Yes	NCTL-210-3367-1/ATLNC 1118.01-14/ATLNC 1031.01-16 Maximum Panel Size: 3'0" x 8'0" Anchor Details-MA-FL0173-07/W-1807/W-1835/W-1885/W-2106
XX Double	I/S	Glazed	6'0" x 8'0"	+43/-47	0 psf	Yes	NCTL-210-3367-1/ATLNC 1118.01-14/ATLNC 1031.01-16 Maximum Panel Size: 3'0" x 8'0" Anchor Details-MA-FL0173-07/W-1807/W-1885/W-2106
XX Double	O/S	Glazed	6'0" x 8'0"	+47/-45 +55/-55 w/Surface Bolts	3.75 psf/ 6.0 psf ¹ 8.25 psf ² /8.25 psf ⁴	Yes	NCTL-210-3367-1/ATLNC 1118.01-14/ATLNC 1031.01-16 Maximum Panel Size: 3'0" x 8'0" Anchor Details-MA-FL0173-07/W-1807/W-1835/W-1885/W-2106
XO/OX Single w/Sidelite	I/S	Glazed Door Glazed Sidelite	6'0" x 8'0"	+43/-47	0 psf	Door-Yes Sidelite-Yes	NCTL-210-3367-1/ATLNC 1118.01-14/ATLNC 1031.01-16 Maximum Panel Size: 3'0" x 8'0" Anchor Details-MA-FL0173-07/W-1807/W-1885/W-2106
XO/OX Single w/Sidelite	O/S	Glazed Door Glazed Sidelite	6'0" x 8'0"	+47/-45 +55/-55 w/Surface Bolts	3.75 psf/ 6.0 psf ¹ 8.25 psf ² /9.0 psf ⁴	Door-Yes Sidelite-Yes	NCTL-210-3367-1/ATLNC 1118.01-14/ATLNC 1031.01-16 Maximum Panel Size: 3'0" x 8'0" Anchor Details-MA-FL0173-07/W-1807/W-1835/W-1885/W-2106
OXO Single w/Sidelites	I/S	Glazed Door Glazed Sidelites	9'0" x 8'0"	+43/-47	0 psf	Door-Yes Sidelite-Yes	NCTL-210-3367-1/ATLNC 1118.01-14/ATLNC 1031.01-16 Maximum Panel Size: 3'0" x 8'0" Anchor Details-MA-FL0173-07/W-1807/W-1885/W-2106
OXO Single w/Sidelites	O/S	Glazed Door Glazed Sidelites	9'0" x 8'0"	+47/-45 +55/-55 w/Surface Bolts	3.75 psf/ 6.0 psf ¹ 8.25 psf ² /9.0 psf ⁴	Door-Yes Sidelite-Yes	NCTL-210-3367-1/ATLNC 1118.01-14/ATLNC 1031.01-16 Maximum Panel Size: 3'0" x 8'0" Anchor Details-MA-FL0173-07/W-1807/W-1835/W-1885/W-2106
OXXO Double w/Sidelites	I/S	Glazed Doors Glazed Sidelites	12'6" x 8'0"	+43/-47	0 psf	Door-Yes Sidelite-Yes	NCTL-210-3367-1/ATLNC 1118.01-14/ATLNC 1031.01-16 Maximum Panel Size: 3'0" x 8'0" Anchor Details-MA-FL0173-07/W-1807/W-1885/W-2106
OXXO Double w/Sidelites	O/S	Glazed Doors Glazed Sidelites	12'6" x 8'0"	+47/-45 +55/-55 w/Surface Bolts	3.75 psf/ 6.0 psf ¹ 8.25 psf ² /8.25 psf ⁴	Door-Yes Sidelite-Yes	NCTL-210-3367-1/ATLNC 1118.01-14/ATLNC 1031.01-16 Maximum Panel Size: 3'0" x 8'0" Anchor Details-MA-FL0173-07/W-1807/W-1835/W-1885/W-2106

1 -Denotes Z-Series Threshold Design 2 -Denotes High Dam Threshold Design 3-W-1815 4-Denotes Worldwide Pro T4 Threshold

National Accreditation & Management Institute, Inc./4794 George Washington Memorial Highway/Hayes, VA 23072

Tel: (804) 684-5124/nami@namiinc.com

NAMI AUTHORIZED SIGNATURE: _____