

AAMA CERTIFICATION PROGRAM



AUTHORIZATION FOR PRODUCT CERTIFICATION

Simonton Windows
1 Cochrane Ave.
Pennsboro, WV 26415

Attn: Tina Jenkins

The product described below is hereby approved for listing in the next issue of the AAMA Certified Products Directory. The approval is based on successful completion of tests, and the reporting to the Administrator of the results of tests, accompanied by related drawings, by an AAMA Accredited Laboratory.

1. The listing below will be added to the next published AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-05 C-R55-914x1270 (36x50)	AAMA 506	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
COMPANY	Missile Level: D Rating: +55/-55, 36x50 Wind Zone: 4 Rating above conforms to requirements of: ASTM E1886 and E1996	5318	08-09/08-20 CASEMENT (PVC) (X) (OG) (INS TEMP/LAM GL) (MODIF) (ASTM)	<u>FRAME(mm)</u> 914 x 1270 (3'0" x 4'2")	<u>VENT(mm)</u> 870 x 1226 (2'10" x 4'0")
Simonton Windows Code: SIM					

2. This Certification will expire **September 13, 2019 (extended from September 13, 2014 per AAMA 103-14a)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

3. Structural Test & Report By:

Architectural Testing, Inc.

Report No: **A4519.01-501-47**

Date of Report: **October 15, 2010**

Missile Impact Test & Report by:

Architectural Testing, Inc.

Report No: **A7004.01-501-47/ Ref. A2063.01-501-47 Rev.1**

Date of Report: **February 23, 2011;
October 7, 2010 (Revised May 25, 2012)**

*****NOTE: ALL CERTIFIED PRODUCTS MUST BE PRODUCED WITH TEMPERED AND LAMINATED GLASS.*****

Validated for Certification

Associated Laboratories, Inc.

Authorized for Certification

American Architectural Manufacturers Association

Date: **October 19, 2010**
Revised: **January 5, 2015**
Cc: AAMA
SBS