

**AAMA  
CERTIFICATION PROGRAM**



**AUTHORIZATION FOR PRODUCT CERTIFICATION**

**Simonton Windows**  
1 Cochrane Ave.  
Pennsboro, WV 26415

**Attn: Tina Jenkins**

The product described below is hereby approved for listing in the next issue of the AAMA Certified Products Directory. The approval is based on successful completion of tests, and the reporting to the Administrator of the results of tests, accompanied by related drawings, by an AAMA Accredited Laboratory.

1. The listing below will be added to the next published AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-05 C-R55-762x1651 (30x65)	AAMA 506	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
<b>COMPANY</b>	Missile Level: <b>D</b> Rating: <b>+55/-55, 30x65</b> Wind Zone: <b>4</b> Rating above conforms to requirements of: <b>ASTM E1886</b> and <b>E1996</b>				
<b>Simonton Windows</b> Code: <b>SIM</b>		<b>5317</b>	<b>08-09/08-20 CASEMENT (PVC) (X) (OG) (INS TEMP/LAM GL) (MODIF) (ASTM)</b>	<u>FRAME(mm)</u> <b>762 x 1651 (2'6" x 5'5")</b>	<u>VENT(mm)</u> <b>718 x 1601 (2'4" x 5'3")</b>

2. This Certification will expire **September 14, 2019 (extended from September 14, 2014 per AAMA 103-14a)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

3. Structural Test & Report By:

**Architectural Testing, Inc.**

Report No: **A4519.01-501-47**

Date of Report: **October 15, 2010**

Missile Impact Test & Report by:

**Architectural Testing, Inc.**

Report No: **A6998.01-501-47; Ref. A2065.01-501-47 Rev.1**

Date of Report: **February 24, 2011;**  
**October 6, 2010 (Revised May 25, 2012)**

**\*\*\*NOTE: ALL CERTIFIED PRODUCTS MUST BE PRODUCED WITH TEMPERED AND LAMINATED GLASS.\*\*\***

Validated for Certification

Associated Laboratories, Inc.

Authorized for Certification

American Architectural Manufacturers Association

Date: **October 19, 2010**  
Revised: **January 5, 2015**  
Cc: AAMA  
SBS