



AUTHORIZATION FOR PRODUCT CERTIFICATION

**Simonton Windows
1 Cochrane Dr.
Pennsboro, WV 26415**

Attn: Tina Seese

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-08 R-PG45-1842x1829 (73x72)-C	AAMA 506				
COMPANY AND CODE	Missile Level: C Rating: +45/-45, 73x72 Wind Zone: 2	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
Simonton Windows Code: SIM	Rating above conforms to the requirements of: ASTM E1886 and E1996	14636	42-19 TWIN CASEMENT (PVC)(XX)(OG) (INS TEMP/PVB LAM GL) (REINF)(ASTM)	<u>FRAME (mm)</u> 1842 x 1829 (6'1" x 6'0")	<u>VENTS (mm)</u> 867 x 1781 (2'10" x 5'10")

This Certification will expire **April 4, 2021 (extended from April 4, 2016 per AAMA 103-15)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Structural Test & Report By:
Architectural Testing, Inc.
Report No: **B7702.01-501-47**
Date of Report: **April 20, 2012**

Missile Impact Test & Report By:
PRI Construction Materials Technologies, LLC
Report No: **SIMO-014-03-13**
Date of Report: **October 9, 2015**

Evaluated for Certification: **December 14, 2016 (Revised December 15, 2016)**

Associated Laboratories, Inc.

Authorized for Certification: **December 14, 2016 (Revised December 15, 2016)**

American Architectural Manufacturers Association