

NOTICE OF PRODUCT CERTIFICATION



Company: Masonite International Corporation
 1955 Powis Road
 West Chicago, IL 60185

Certification No.: NI013747.01-R2
Certification Date: 06/08/2017
Expiration Date: 06/30/2025
Revision Date: 07/27/2020

Product: Wood-Edge Steel Full-Lite Glazed Inswing or Outswing Door w/Non-Impact Rated Sidelites
 (Requires "HPC" Construction Slabs) (w/Wood Frame unless noted)

Specification: TAS 202-94/ASTM E330-02

Glazing: Insulating Glass (Tempered)

The "Notice of Product Certification" is only valid if the NAMI Certification Label has been applied to the product as described within this document. The certification label represents product conformity to the applicable specification and that all certification criteria has been satisfied. This product has been approved for listing within NAMI's Certified Product Listing at www.Namicertification.com. NAMI's Certification Program is accredited by The American National Standards Institute (ANSI).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Structural Design Pressure	Water Test Pressure	Missile Impact Rated	Test Report Number Drawing Number & Comments
X Single	I/S	Glazed	3'0" x 6'8"	+50/-50	0.0 psf	No	NCTL-110-19469-6 Maximum Panel Size: 3'0" x 6'8" Anchor Details-DWG-MA-FL0212-17
X Single	O/S	Glazed	3'0" x 6'8"	+50/-50	3.0 psf ¹ 4.5 psf ² 7.50 psf ^{3,4,5}	No	NCTL-110-19469-6/W-1857 Maximum Panel Size: 3'0" x 6'8" Anchor Details-DWG-MA-FL0212-17
XX Double	I/S	Glazed	6'0" x 6'8"	+50/-50	0 psf	No	NCTL-110-19469-6 Maximum Panel Size: 3'0" x 6'8" Anchor Details-DWG-MA-FL0212-17
XX Double	O/S	Glazed	6'0" x 6'8"	+50/-50	3.0 psf ¹ 4.5 psf ² 7.50 psf ³	No	NCTL-110-19469-6 Maximum Panel Size: 3'0" x 6'8" Anchor Details-DWG-MA-FL0212-17
XO/OX Single w/Sidelite	I/S	Glazed	6'0" x 6'8"	+50/-50	0 psf	Door-No Sidelite-No	NCTL-110-19469-6 Maximum Panel Size: 3'0" x 6'8" /Sidelite: 3'0" x 6'8" Anchor Details-DWG-MA-FL0212-17
XO/OX Single w/Sidelite	O/S	Glazed	6'0" x 6'8"	+50/-50	3.0 psf ¹ 4.5 psf ² 7.50 psf ³	Door-No Sidelite-No	NCTL-110-19469-6 Maximum Panel Size: 3'0" x 6'8" /Sidelite: 3'0" x 6'8" Anchor Details-DWG-MA-FL0212-17
OXO Single w/Sidelites	I/S	Glazed	9'0" x 6'8"	+50/-50	0 psf	Door-No Sidelite-No	NCTL-110-19469-6 Maximum Panel Size: 3'0" x 6'8" /Sidelite: 3'0" x 6'8" Anchor Details-DWG-MA-FL0212-17
OXO Single w/Sidelites	O/S	Glazed	9'0" x 6'8"	+50/-50	3.0 psf ¹ 4.5 psf ² 7.50 psf ³	Door-No Sidelite-No	NCTL-110-19469-6 Maximum Panel Size: 3'0" x 6'8" /Sidelite: 3'0" x 6'8" Anchor Details-DWG-MA-FL0212-17
OXXO Double w/Sidelites	I/S	Glazed	12'4" x 6'8"	+50/-50	0 psf	Door-No Sidelite-No	NCTL-110-19469-6 Maximum Panel Size: 3'0" x 6'8" /Sidelite: 3'0" x 6'8" Anchor Details-DWG-MA-FL0212-17
OXXO Double w/Sidelites	O/S	Glazed	12'4" x 6'8"	+50/-50	3.0 psf ¹ 4.5 psf ² 7.50 psf ³	Door-No Sidelite-No	NCTL-110-19469-6 Maximum Panel Size: 3'0" x 6'8" /Sidelite: 3'0" x 6'8" Anchor Details-DWG-MA-FL0212-17

1 -Denotes Bumper Outswing Threshold 2 -Denotes Z-Series Outswing Threshold 3-Hi-Dam Outswing Threshold 4-Pro T4 Threshold 5-HP Outswing Threshold

National Accreditation & Management Institute, Inc./4794 George Washington Memorial Highway/Hayes, VA 23072

Tel: (804) 684-5124/Fax: (804) 684-5122

NAMI AUTHORIZED SIGNATURE: _____

A handwritten signature in black ink, appearing to be 'SMD', is written over a horizontal line.