

Hallmark® Certificate of Conformance and License (CCL)



Kolbe & Kolbe Millwork Co.
1323 South 11th Avenue
Wausau, WI 54401

Mfr ID: 416


For more Information visit www.amscert.com

Website: www.kolbewindows.com

TEL:

<i>Product No.</i>	<i>Product Name</i>	<i>Standard</i>	<i>Rating</i>	<i>Wide</i>	<i>High</i>	<i>Test Report #</i>	<i>CertDate</i>	<i>ExpDate</i>
416-H-1033.10	Forgent Sliding Patio Door 14-0x8-0 OXXO (R&D #19046)	101/I.S.2/A440-17	Class LC-PG40; Size Tested 4255mm x 2426mm Type-SD; DP +40/-45 psf; Water Test Press 290Pa (6.06psf); Can. Air Infil/Exfil. Level=A2	4255mm	2426mm	QCT19-5424.01	1/10/2020	6/27/2029
416-H-1033.11	Forgent Sliding Patio Door 14-0x8-0 OXXO (R&D #19046)	101/I.S.2/A440-11	Class LC-PG40; Size Tested 4255mm x 2426mm Type-SD; DP +40/-45 psf; Water Test Press 290Pa (6.06psf); Can. Air Infil/Exfil. Level=A2	4255mm	2426mm	QCT19-5424.01	1/10/2020	6/27/2029
416-H-1033.15	Forgent Sliding Patio Door 14-0x8-0 OXXO (R&D #19046)	ASTM E-1996 17/ASTM E-1886 13a	DP +40/-45 psf, Missile D, Wind Zone 4	4255mm	2426mm	QCT19-5424.01	1/10/2020	6/27/2029

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  John McFee, VP of Certification Programs, WDMA Hallmark

By:  Lucas L. Wenzel, Authorized Representative, AMS

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com