

**AAMA  
CERTIFICATION PROGRAM**



**AUTHORIZATION FOR PRODUCT CERTIFICATION**

**Simonton Windows  
1 Cochrane Dr.  
Pennsboro, WV 26415**

**Attn: Tina Seese**

The product described below is hereby approved for listing in the next issue of the AAMA Certified Products Directory. The approval is based successful completion of tests, and the reporting to the Administrator of the results of tests, accompanied by related drawings, by an AAMA Accredited Laboratory.

1. The listing below will be added to the next published AAMA Certified Products Directory.


SPECIFICATIONS		RECORD OF PRODUCT TESTED		
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08 R-PG50*-940x2134 (37x84)-FW</b>	<b>AAMA 506</b>			
COMPANY AND CODE	Missile Level: D Rating: +50/-50, 37x84 Wind Zone: 4	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED
<b>Simonton Windows Code: SIM</b>	Rating above conforms to the requirements of: <b>ASTM E1886 and E1996</b>	<b>5316</b>	<b>07-09 PW (PVC)(O)(IG) (INS TEMP/PVB LAM GL) (ASTM)</b>	<b>FRAME 940 mm x 2134 mm (3'1" x 7'0")</b>

2. This Certification will expire **June 23, 2019 (extended from June 23, 2016 per AAMA 103-15)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

3. Structural Test & Report By:  
**Architectural Testing, Inc.**  
Report No: **A2066.01-501-44**  
Date of Report: **July 7, 2010**

Missile Impact Test & Report By:  
**Architectural Testing, Inc.**  
Report No: **99620.01-501-47**  
Date of Report: **August 30, 2010 (Revised May 30, 2012)**

**Validated for Certification**

  
Associated Laboratories, Inc.

Date: **March 24, 2016**

Cc: AAMA  
JGS  
ACP-14 (Rev. 1/11)

**Authorized for Certification**

  
American Architectural Manufacturers Association