

Hallmark® Certificate of Conformance and License (CCL)




JELD-WEN INC.
401 Harbor Isles Boulevard
Klamath Falls, OR 97601

Mfr ID: 406
For more Information visit www.amscert.com
Website: WWW.JELD-WEN.COM
TEL: (541) 882-3451

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
406-H-802.09	Siteline or W-5500 Clad Out-Swing Transom (O) - IG Impact	101/I.S.2/A440-11	Class LC-PG50; Size Tested 1920mm x 915mm * Type-TR; DP +50/-55 psf	1920mm	915mm	SJW2016-051	3/2/2017	1/3/2026
406-H-802.10	Siteline or W-5500 Clad Out-Swing Transom (O) - IG Impact	ASTM E-1996 14/ASTM E-1886 13a	DP +50/-55 psf, Missile D, Wind Zone 3	1920mm	915mm	SJW2016-051	3/2/2017	1/3/2026

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  John McFee, VP of Certification Programs, WDMA Hallmark

By:  Lucas L. Wenzel, Authorized Representative, AMS

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com