

# Hallmark® Certificate of Conformance and License (CCL)



Kolbe & Kolbe Millwork Co.  
1323 South 11th Avenue  
Wausau, WI 54401

*Mfr ID:* 413

*For more Information visit* [www.amscert.com](http://www.amscert.com)

*Website:* [www.kolbewindows.com](http://www.kolbewindows.com)

*TEL:*

<i>Product No.</i>	<i>Product Name</i>	<i>Standard</i>	<i>Rating</i>	<i>Wide</i>	<i>High</i>	<i>Test Report #</i>	<i>CertDate</i>	<i>ExpDate</i>
413-H-1176.18	Heritage XL Sterling Double Hung, SP (R&D 15132)	101/I.S.2/A440-11	Class LC-PG60; Size Tested 1219mm x 3061mm Type-H; DP +60/-60 psf; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=A2	1219mm	3061mm	QCT16-3890.01	11/17/2017	10/10/2027

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

*By:*  John McFee, VP of Certification Programs, WDMA Hallmark

*By:*  Lucas L. Wenzel, Authorized Representative, AMS

Program Sponsor:  
Window and Door Manufacturers Assoc  
330 N. Wabash Avenue, Suite 2000  
Chicago, IL 60611  
TEL (312)673-4828 [www.wdma.com](http://www.wdma.com)

Program Administrator:  
Administrative Management Systems, Inc.  
PO Box 730, 205 West Main  
Sackets Harbor, NY 13685  
TEL (315)646-2234 [staff@amscert.com](mailto:staff@amscert.com)