

# Hallmark® Certificate of Conformance and License (CCL)



Kolbe & Kolbe Millwork Co.  
1323 South 11th Avenue  
Wausau, WI 54401

*Mfr ID:* 413


*For more Information visit* [www.amscert.com](http://www.amscert.com)


*Website:* [www.kolbewindows.com](http://www.kolbewindows.com)

*TEL:*

<i>Product No.</i>	<i>Product Name</i>	<i>Standard</i>	<i>Rating</i>	<i>Wide</i>	<i>High</i>	<i>Test Report #</i>	<i>CertDate</i>	<i>ExpDate</i>
413-H-1225.25	Ultra Sterling Double Hung, single glaze & insulated, IPD4 (R&D 18095/18096)	101/I.S.2/A440-17	Class LC-PG65; Size Tested 1156mm x 2043mm Type-H; DP +65/-70 psf; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=A3	1156mm	2043mm	ESP029764P-2381	7/1/2019	4/22/2029
413-H-1225.28	Ultra Sterling Double Hung, single glaze & insulated, IPD4 (R&D 18095/18096)	ASTM E-1996 17/ASTM E-1886 13a	DP +65/-70 psf, Missile D, Wind Zone 4	1156mm	2043mm	ESP029764P-2381	7/1/2019	4/22/2029

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

*By:*  John McFee, VP of Certification Programs, WDMA Hallmark

*By:*  Lucas L. Wenzel, Authorized Representative, AMS

Program Sponsor:  
Window and Door Manufacturers Assoc  
330 N. Wabash Avenue, Suite 2000  
Chicago, IL 60611  
TEL (312)673-4828 [www.wdma.com](http://www.wdma.com)

Program Administrator:  
Administrative Management Systems, Inc.  
PO Box 730, 205 West Main  
Sackets Harbor, NY 13685  
TEL (315)646-2234 [staff@amscert.com](mailto:staff@amscert.com)