

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI013981.32-R1  
**DATE:** 04/08/2019  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** JELD-WEN  
**CODE:** 1822-1  
**REVISION DATE:** 07/27/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>JELD-WEN</b> <b>3737 Lakeport Boulevard</b> <b>Klamath Falls, OR 97601</b>	<b>Series "Architectural 3-Lite" Glazed Fiberglass In-Swing Side-Hinged Door</b>  Configuration: X Glazing: Insulated Glass (Tempered)  Frame: W-949mm(37.38")    H-2077mm(81.75") Panel: W-909mm(35.88")    H-2006mm(79") DLO: W-537mm(21.13")    H-410mm(16.13")

SPECIFICATION	PRODUCT RATING
<b>TAS 202-94</b>	<b>Design Pressure: 2400 Pa (50 psf)</b> <b>Positive Design Pressure: 2400 Pa (50 psf)</b> <b>Negative Design Pressure: 2640 Pa (55 psf)</b> Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf)

Product Tested By: Intertek Group, PLC  
Report No: J4270.01-301-47  
Expiration Date: **February 28, 2028**

Administrator's Signature: \_\_\_\_\_  


**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Email: [nami@namiinc.com](mailto:nami@namiinc.com)