

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013981.33-R1
DATE: 04/08/2019
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 07/27/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Architectural 3-Lite" Glazed Fiberglass Out-Swing Side-Hinged Door Configuration: X Glazing: Insulated Glass (Tempered) Frame: W-949mm(37.38") H-2077mm(81.75") Panel: W-909mm(35.88") H-2006mm(79") DLO: W-537mm(21.13") H-410mm(16.13")

SPECIFICATION	PRODUCT RATING
TAS 202-94	Design Pressure: 2400 Pa (50 psf) Positive Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2640 Pa (55 psf) Water Penetration Resistance Test Pressure: 400 Pa (8.35 psf)

Product Tested By: Intertek Group, PLC
Report No: J4271.01-301-47
Expiration Date: **February 28, 2028**

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com