

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013981.36-R1
DATE: 04/15/2019
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 07/27/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Architectural" Glazed Full Lite Fiberglass Out-Swing Side-Hinged Door Configuration: X Glazing: Insulated Glass (Tempered) Frame: W-953mm(37.5") H-2038mm(80.25") Panel: W-905mm(35.63") H-2007mm(79") DLO: W-537mm(21.13") H-1600mm(63")

SPECIFICATION	PRODUCT RATING
TAS 202-94	Design Pressure: 2400 Pa (50 psf) Positive Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2640 Pa (55 psf) Water Penetration Resistance Test Pressure: 400 Pa (8.25 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-310-19-041
Expiration Date: **March 31, 2028**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com